



A P P R O V A L S ®

Certificate of Approval

Certificate No.: SAA-171228-EA

Certificate Holder: Mean Well Enterprises Co., Ltd.
No. 28, Wuquan 3rd Rd., Wugu Dist.,
New Taipei City 248,
Taiwan

Class Description: Power Supply or Charger
Product Description: LED Controlgear
(Independent SELV, Constant Voltage)

Brand Name: MEAN WELL

Model No.: APV-12-. Series

Markings: Input: 100-240Vac 50/60Hz 0.35A
Output: 5-24Vdc, 2A Max, 12W Max
ta:45°C tc:70°C, IP42, Class II

Standard: AS/NZS 61347.2.13:2013

AS/NZS 61347.1:2016

Conditions: Nil

Approval Mark: SAA-171228-EA or RCM

Date First Registered: 7 June 2017

Date of Expiry: 7 June 2022


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



Issued: 07-06-17 171228/1

www.jas-anz.org/register



A P P R O V A L S ®

Certificate of Approval

* Addendum *

Certificate No.: SAA-171228-EA

Date of Issue: 7 June 2017

Class Description: Power Supply or Charger
Product Description: LED Controlgear
(Independent SELV, Constant Voltage)

General Modification:

'!' in model number denotes output voltage (Vdc) and can be '5', '12', '15' or '24'.

Additional Models	Description
APV-16-. Series	Similar to APV-12-. Series except with potting compound and rated: Input: 100-240Vac 50/60Hz 0.5A Output: 5-24Vdc, 2.6A Max, 16.08W Max ta:40°C tc:70°C
APV-12E-. Series	Similar to APV-12-. Series except rated: Input: 200-240Vac 50/60Hz 0.2A Output: 5-24Vdc, 2.0A Max, 12W Max ta:45°C tc:70°C
APV-16E-. Series	Similar to APV-12E-. Series except rated: Input: 200-240Vac 50/60Hz 0.3A Output: 5-24Vdc, 2.6A Max, 16.08W Max ta:40°C tc:70°C


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 07-06-17 171228/2