



## UK Declaration of Conformity

For the following equipment :

Product Name: 4 Channels 5KW Energy Recycling Grid Type Power Inverter

Model Designation: ERG-5000(x=Blank or H)

The designated product(s) is(are) in conformity with the relevant legislation:

**The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012:** SI 2012 No. 3032

**Electrical Equipment (Safety) Regulations 2016 :**

BS EN 62368-1:2014+A11:2017

LVD Report No : MWGP LVD-2022-001

**Electrical Compatibility Regulations 2016 :**

**EMI (Electro-Magnetic Interference)**

Conducted emission/ Radiated emission

BS EN 55032:2015+A11:2020

Class A

**EMS (Electro-Magnetic Susceptibility)**

BS EN 55035:2017+A11:2020

ESD air	BS EN 61000-4-2:2009	Level 3	8KV
ESD contact	BS EN 61000-4-2:2009	Level 2	4KV
RF field susceptibility	BS EN IEC 61000-4-3:2020	Level 2	3V/m
EFT bursts	BS EN 61000-4-4:2012	Level 2	1KV/5KHz
Surge susceptibility	BS EN 61000-4-5:2014+A1:2017	Level 3	1KV/Line-Line
Surge susceptibility	BS EN 61000-4-5:2014+A1:2017	Level 3	2KV/Line-Earth
Conducted susceptibility	BS EN 61000-4-6:2014	Level 2	3V

**Note:**

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number TC2xxxxxxx

**Person responsible for marking this declaration :**

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D :

(Name / Position)

(Signature)

Alex Tsai/ Director, Product Strategy Center :

(Name / Position)

(Signature)

Taiwan

(Place)

Nov. 15th, 2022

(Date)