



Declaration of Conformity

For the following equipment :

Product Name: Enclosed Type Redundancy Module

Model Designation: ERDN20, ERDN40

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU) 、 (EU)2015/863

Low Voltage Directive (2014/35/EU) :

EN 62368-1:2014+A11:2017

CB certificate No : DK-87580-UL

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN 55032:2015+A11:2020

Class B

EMS (Electro-Magnetic Susceptibility)

EN 55035:2017+A11:2020 EN IEC 61000-6-2:2019

ESD air EN 61000-4-2:2009 Level 4 15KV

ESD contact EN 61000-4-2:2009 Level 4 8KV

RF field susceptibility EN IEC 61000-4-3:2020 Level 3 10V/m

EFT bursts EN 61000-4-4:2012 Level 3 2KV/5KHz

Surge susceptibility EN 61000-4-5:2014+A1:2017 Level 3 1KV/Line-Line

Surge susceptibility EN 61000-4-5:2014+A1:2017 Level 3 2KV /Line-Earth

Conducted susceptibility EN 61000-4-6:2014 Level 3 10V

Magnetic field immunity EN 61000-4-8:2010 Level 4 30A/m

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number SC1xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D:

(Name / Position)

Aries
(Signature)

Alex Tsai/ Director, Product Strategy Center:

(Name / Position)

[Signature]
(Signature)

Taiwan

(Place)

Oct.18th, 2021

(Date)